

CLAY-ROANE PSD (PROCIOS DISTRICT)

WV3300806

Consumer Confidence Report – 2026

Covering Calendar Year – 2025

This report is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments or suggestions, please attend any regularly scheduled water board meeting held on the **2nd Thursday** of each month at **6:00 PM** in the **Clay Roane PSD Treatment Plant** or call CRYSTAL D. ADKINS at 304-548-5209.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from Surface water:

Source Name	Source Water Type
CC FROM WV3300801 CLAY WATER DEPT	Surface water
ELK RIVER - INTAKE	Surface water

Buyer Name	Seller Name
WV3300806 - CLAY-ROANE PSD (PROCIOS DISTRICT)	CLAY WATER DEPT

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and come from gas stations, urban storm water run-off, and septic systems.

To ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 2199 and is required to test a minimum of 2 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all the drinking water contaminants which were detected during the 2025 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2025. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: CLAY-ROANE PSD (PROCIOS DISTRICT)

Regulated Contaminants	Facility Name	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	TREATMENT PLANT	3/26/2025	0.0313	0.0313	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
NITRATE	TREATMENT PLANT	3/26/2025	0.21	0.21	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	TREATMENT PLANT	3/29/2024	0.27	0.27	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Collection Date	Highest LRAA Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	780 REED FORK RD (ADKINS RESIDENCE)	2025	32	29 - 35	ppb	60	0	By-product of drinking water disinfection
TTHM	780 REED FORK RD (ADKINS RESIDENCE)	2025	29	24 - 33	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90TH Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.315	0.005 - 1.1814	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	1	0 - 2.2	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CLAY-ROANE PSD (PROCIOS DISTRICT) is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CLAY-ROANE PSD (PROCIOS DISTRICT) and CRYSTAL D. ADKINS at 304-548-5209. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

CLAY-ROANE PSD (PROCIOS DISTRICT) completed lead tap sampling in 2021 - 2023 the results are available for review and can be accessed at Clay-Roane PSD water treatment plant.

CLAY-ROANE PSD (PROCIOS DISTRICT) has prepared a service line inventory identifying service line materials throughout the water distribution supply. The most up to date inventory is located at **Clay-Roane PSD water treatment plant**. By November 1, 2027, our water system must develop an updated initial inventory, known as the "baseline inventory" and it must include each service line and identified connector that is connected to the public water distribution system.

Our water system identified **no lead, no galvanized requiring replacement, and no lead status unknown** service lines in our inventory. Due to this identification our water system must create a service line replacement plan by November 1, 2027.

If you have any questions about our inventory or if you would like information about our service line replacement plan, please contact CRYSTAL D. ADKINS at 304-548-5209.

Source Water Assessment and Protection

When required by West Virginia State law, CLAY-ROANE PSD (PROCIOSUS DISTRICT) maintains a comprehensive **Source Water Protection Plan (SWPP)** that is updated every three years and reviewed by the West Virginia Bureau for Public Health (WVBPH). For systems utilizing surface water or groundwater under the direct influence of surface water (GWUDI), SWPPs provide a detailed strategy for protecting intake areas and the surrounding Zone of Critical Concern.

Because these types of sources are open to the environment, they generally have a higher susceptibility to contamination. This susceptibility rating does not mean your water is contaminated; rather, it indicates that conditions exist which could impact the source water if a release occurred due to the sensitive nature of the intake area. A public version of our current Source Water Protection Plan (if applicable) or further information regarding our specific source susceptibility is available for review at our office during normal business hours or by contacting CRYSTAL D. ADKINS at 304-548-5209. A Source Water Assessment may previously have been completed to identify potential sources of contamination and the susceptibility of our water source. You can view these historical assessment reports online at the WVBPH website: <https://www.wvdhhr.org/oehs/eed/swap/search.cfm>. For more information on source water protection and to learn how you can help protect drinking water sources, visit the EPA at <https://www.epa.gov/sourcewaterprotection/how-can-you-help-protect-source-water>.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
3/1/2025 - 3/31/2025	1.97000	MG/L	1.60000	MG/L

AVAILABILITY OF MONITORING DATA FOR UNREGULATED CONTAMINANTS

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that do not yet have a drinking water standard set by the US Environmental Protection Agency (EPA). The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available.

If you are interested in examining the results, please contact: Crystal D. Adkins at 304-548-5209.

Unresolved Deficiency Date Identified	Facility	Comments
8/16/2023	TREATMENT PLANT	The chlorine room does not have a properly functioning leak detector. (64CSR77-7.4.c) Please ensure the chlorine room has a properly functioning leak detector. Not having a properly functioning chlorine leave detector is an extreme danger to the staff of the system, the visitors to the office, and even others nearby such as residents in nearby houses or possibly even fishermen floating by on the river. Besides a safety issue it also poses a liability issue should someone be exposed to chlorine gas with no warning from a leak detector system.
8/16/2023	WATER SYSTEM	The system utilizes very old monitoring equipment. For instance, the system is using a Hach 1720E in-line turbidimeter with an sc100 controller. This instrument is reportedly no longer being supported by the manufacturer and thus cannot be properly calibrated. The system is using a benchtop to verify values but calibration of the inline can't be done properly at this time. Since monitoring equipment is not properly calibrated (64CSR77-4.9) the system should review all monitoring equipment for replacement with newer currently supported instruments which can be properly calibrated. Please ensure all monitoring equipment is properly calibrated.

Total Organic Carbon Lowest Month for Removal	Facility Name	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	INTAKE	12/4/2025	2.17	0.82 - 2.17	MG/L	0	Naturally present in the environment

Analyte	Facility Name	Highest Value	Unit of Measure	Month Occurred
Turbidity	TREATMENT PLANT	0.28	NTU	February

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	3/7/2022	0.019	0.019	µg/L	30	0	Erosion of natural deposits
RADIUM-228	3/7/2022	0.135	0.135	pCi/L	0	0	Erosion of natural deposits

Turbidity

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Percentage of samples in compliance with Std	Months Occurred	Violation	Highest Single Measurement	Month Occurred	Sources	Level Indicator
100.00	12	NO	0.28	February	TREATMENT PLANT	Yes

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

TOC	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	12/4/2025	2.17	0.82 - 2.17	MG/L	0	Naturally present in the environment

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
NICKEL	3/26/2025	1	1	UG/L	0
SODIUM	3/26/2025	11.4	11.4	MG/L	20

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

Fed Rep ID	Compliance Period	Violation Type	Category	Rule	Explanation	Actions Taken by Water System
214600	1/1/2025 - 3/31/2025	MONITORING, ROUTINE (DBP), MAJOR	MON	ALKALINITY, TOTAL	Failed to monitor/report as required for chlorine or disinfection by-products	Resampled 3.27.25

AVAILABILITY OF MONITORING DATA FOR UNREGULATED CONTAMINANTS

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that do not yet have a drinking water standard set by the US Environmental Protection Agency (EPA). The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available.

If you are interested in examining the results, please contact: Crystal D. Adkins at 304-548-5209

Testing Results for: Clay Water Department

Reseller Contaminants

Regulated Contaminants	Facility Name	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ANTIMONY, TOTAL	TREATMENT PLANT	7/9/2024	CLAY WATER DEPT	0.025	0.025	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics;s older
BARIUM	TREATMENT PLANT	7/9/2024	CLAY WATER DEPT	0.0534	0.0534	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CARBON, TOTAL	INTAKE-ELK RIVER	1/9/2024	CLAY WATER DEPT	1.2	1.1 - 1.2	ppm	10000	0	Naturally present in the environment
NITRATE	TREATMENT PLANT	7/10/2025	CLAY WATER DEPT	0.056	0.056	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	TREATMENT PLANT	7/9/2024	CLAY WATER DEPT	0.054	0.053 - 0.054	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Water System	Highest RAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2025	CLAY WATER DEPT	36	31 - 40	ppb	60	0	By-product of drinking water disinfection
TTHM	2025	CLAY WATER DEPT	45	36 - 54	ppb	80	0	By-product of drinking water chlorination

Secondary Contaminants.	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
NICKEL	7/9/2024	CLAY WATER DEPT	0.6	0.6	UG/L	0
SODIUM	7/9/2024	CLAY WATER DEPT	6.49	6.49	MG/L	20

COPPER, FREE	2022 - 2024	0.029	0.0012 - 0.0368	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2022 - 2024	2.6	0.05 - 6	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Please Note: Because of sampling schedules, results may be older than 1 year. During the 2025 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.							
Water System	Fed Rep ID	Compliance Period	Violation Type	Category	Rule	Explanation	Actions Taken by Water System
WV3300801	5008110	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	No monitoring samples were taken or reported	
WV3300801	5008099	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	SIMAZINE	No monitoring samples were taken or reported	
WV3300801	5008101	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	PICLORAM	No monitoring samples were taken or reported	
WV3300801	5008098	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	OXAMYL	No monitoring samples were taken or reported	
WV3300801	5008096	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	METHOXYCHLOR	No monitoring samples were taken or reported	
WV3300801	5008105	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	LASSO	No monitoring samples were taken or reported	
WV3300801	5008102	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	HEXACHLOROCHLOROCYCLOPENTADIENE	No monitoring samples were taken or reported	
WV3300801	5008107	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	HEPTACHLOR EPOXIDE	No monitoring samples were taken or reported	
WV3300801	5008106	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	HEPTACHLOR	No monitoring samples were taken or reported	
WV3300801	5008100	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	DI(2-ETHYLHEXYL)	No monitoring samples were	

					PHTHALATE	taken or reported	
WV3300801	5008097	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	DI(2-ETHYLHEXYL) ADIPATE	No monitoring samples were taken or reported	
WV3300801	5008111	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CHLORDANE	No monitoring samples were taken or reported	
WV3300801	5008103	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CARBOFURAN	No monitoring samples were taken or reported	
WV3300801	5008095	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	BHC-GAMMA	No monitoring samples were taken or reported	
WV3300801	5008109	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	BENZO(A) PYRENE	No monitoring samples were taken or reported	
WV3300801	5008104	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	ATRAZINE	No monitoring samples were taken or reported	
WV3300801	5008108	1/1/2023 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	2,4-D	No monitoring samples were taken or reported	
WV3300801	5008115	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	XYLENES, TOTAL	No monitoring samples were taken or reported	
WV3300801	5008119	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	VINYL CHLORIDE	No monitoring samples were taken or reported	
WV3300801	5008126	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	TRICHLOROETHYLENE	No monitoring samples were taken or reported	
WV3300801	5008121	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	TRANS-1,2-DICHLOROETHYLENE	No monitoring samples were taken or reported	
WV3300801	5008131	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	TOLUENE	No monitoring samples were taken or reported	
WV3300801	5008144	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	THALLIUM , TOTAL	No monitoring samples were taken or reported	
WV3300801	5008128	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	TETRACHLOROETHYLENE	No monitoring samples were taken or reported	

WV3300801	5008133	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	STYRENE	No monitoring samples were taken or reported	
WV3300801	5008141	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	SODIUM	No monitoring samples were taken or reported	
WV3300801	5008145	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	SELENIUM	No monitoring samples were taken or reported	
WV3300801	5008118	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	P-DICHLOROBENZENE	No monitoring samples were taken or reported	
WV3300801	5008117	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	O-DICHLOROBENZENE	No monitoring samples were taken or reported	
WV3300801	5008140	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	NICKEL	No monitoring samples were taken or reported	
WV3300801	5008139	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	MERCURY	No monitoring samples were taken or reported	
WV3300801	5008138	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	FLUORIDE	No monitoring samples were taken or reported	
WV3300801	5008132	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	ETHYLBENZENE	No monitoring samples were taken or reported	
WV3300801	5008116	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	DICHLOROMETHANE	No monitoring samples were taken or reported	
WV3300801	5008137	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CYANIDE	No monitoring samples were taken or reported	
WV3300801	5008114	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CIS-1,2-DICHLOROETHYLENE	No monitoring samples were taken or reported	
WV3300801	5008136	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CHROMIUM	No monitoring samples were taken or reported	
WV3300801	5008129	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CHLOROBENZENE	No monitoring samples were taken or reported	
WV3300801	5008124	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CARBON TETRACHLORIDE	No monitoring samples were taken or reported	

WV3300801	5008135	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	CADMIUM	No monitoring samples were taken or reported	
WV3300801	5008143	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	BERYLLIUM, TOTAL	No monitoring samples were taken or reported	
WV3300801	5008130	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	BENZENE	No monitoring samples were taken or reported	
WV3300801	5008134	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	BARIUM	No monitoring samples were taken or reported	
WV3300801	5008112	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	ARSENIC	No monitoring samples were taken or reported	
WV3300801	5008142	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	ANTIMONY, TOTAL	No monitoring samples were taken or reported	
WV3300801	5008125	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,2-DICHLOROPROpane	No monitoring samples were taken or reported	
WV3300801	5008122	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,2-DICHLOROETHANE	No monitoring samples were taken or reported	
WV3300801	5008113	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,2,4-TRICHLOROBENZENE	No monitoring samples were taken or reported	
WV3300801	5008120	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,1-DICHLOROETHYLENE	No monitoring samples were taken or reported	
WV3300801	5008127	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,1,2-TRICHLOROETHANE	No monitoring samples were taken or reported	
WV3300801	5008123	1/1/2025 - 12/31/2025	MONITORING , ROUTINE MAJOR	MON	1,1,1-TRICHLOROETHANE	No monitoring samples were taken or reported	
WV3300801	5008091	2/1/2025 - 2/28/2025	SINGLE COMB FLTR EFFLUENT (IESWTR/LT1)	TT	TURBIDITY	Turbidity exceedance (single sample)	
WV3300801	5008093	6/1/2025 - 6/30/2025	FAILURE TO COMPLETE OR SUBMIT MOR	MON	CHLORINE		

This report will not be mailed. A copy will be made available for review or your use upon request.
Your CCR is available at ***Clay-Roane PSD water treatment plant***. To receive a paper copy in the mail, please contact us at the phone number above.